General Industrial Controls Private Limited



EU & RoHS Declaration of Conformity

We,

General Industrial Controls Private Limited, T-107 & T-114, MIDC, Bhosari, Pune 411 026 (Maharashtra State) India +91-20-46232323, <u>info@gicindia.com</u>; declare under sole responsibility that the following described products in our delivered version comply with the appropriate basic safety and health requirements of the:

1. Low Voltage Directive – 2014/35/EU	2. EMC Directive – 2014/30/EU	3. RoHS Directive 2011/65/EU	

based on its design and type, as brought into circulation by us.

(In case of alteration of the product by the user, not agreed upon by us, this declaration will lose its validity.)

Description of the Product:

Series : SM Series

Nomenclature : Current Monitoring Series

:

Cat ID

17A122CB0	17A122OB0	17B122AA0	17C112EB0	17D112DA0	17B122PA0	17B122MA0	17B822MM0
17A222CB0	17A222OB0	17B222AA0	17C212EB0	17D212DA0	17B222PA0	17B222MA0	XM81058
17A322CB0	17A322OB0	17B322AA0	17C312EB0	17D312DA0	17B322PA0	17B322MA0	XM81059
17A422CB0	17A422OB0	17B422AA0	17C412EB0	17D412DA0	17B422PA0	17B422MA0	17B922MM0

Description

: Current monitoring device with Inverse & Definite timing.

Generally meets Product Standard : IEC 60255-08

Applicable Harmonized Standards: Under EMC & LVD Directives:

Title			
EC 61000-4-2 Electrostatic Discharge (ESD) Immunity Test			
Radiated, radio-frequency, electromagnetic field immunity test			
Electrical Fast Transient / Burst immunity test			
Surge Immunity test			
Conducted Susceptibility			
(Immunity to conducted disturbances, induced by radio-frequency fields)			
Power frequency magnetic field immunity test			
Voltage dips & immunity tests for AC input ports			
Di-electric Strength			
(Safety requirements for electrical equipment for measurement, control, and Laboratory use)			
Conducted & Radiated Emissions			

RoHS Directive 2011/65/EC of the European Parliament & of the council regarding the limitation of dangerous substances,

Year in which CE Marking was affixed: 2018

Name of Company: General Industrial Controls Pvt. Ltd.

Date: 04/02/2019

Name of Signatory	: Rajan Rane	Name of Signatory: Vijay Waykole		Name of Signatory: Shrihari kshirsagar.		
Title / Designation:	: Asst.	Title / Designation: General Manager		Title / Designation: Manager (Quality)		
Manager (Product Engg) (Materi			agement)			
Rajan H. R.	Œ	Mayle	le	S.K	shirsagar	Rohs

Document Ref. No: EC17A19