



General Industrial Controls Private Limited

EU & RoHS Declaration of Conformity

We,

General Industrial Controls Private Limited, T-107 & T-114, MIDC, Bhosari, Pune 411 026 (Maharashtra State) India +91-20-46232323, info@gicindia.com, www.gicindia.com; declare under sole responsibility that the following described products in our delivered version comply with the appropriate basic safety and health requirements of the:

1. Low Voltage Directive – 2014/35/EU	2. EMC Directive – 2014/30/EU	3. RoHS Directive 2011/65/EU
---------------------------------------	-------------------------------	------------------------------

based on its design and type, as brought into circulation by us.

(In case of alteration of the product by the user, not agreed upon by us, this declaration will lose its validity.)

Description of the Product:

Series/ Nomenclature : Signal Transducer

Catalog Numbers:

Sr. No.	Cat. Id.	Description
1.	2SC3D11CC3	SIGNAL TRANSDUCER , 24VDC +/-15% SUPPLY,1 I/P,1 O/P, VOLTAGE+CURRENT, 3 PORT ISOLATION,2M
2.	2SC3D11DC3	SIGNAL TRANSDUCER, 24VDC +/-15% SUPPLY,1 I/P,1 O/P,VOLTAGE(0-5V/1-5V) +CURRENT, 3 PORT ISOLATION,2M
3.	2SC3D11EC3	SIGNAL TRANSDUCER,24VDC +/-15% SUPPLY,1 I/P,1 O/P,VTG.+CURRENT(0-10 mA/2-10mA), 3 PORT ISOLATION,2M

Applicable Harmonized Standards: Under EMC & LVD Directives:

Ref. No.	Title
IEC 61000-4-2	Electrostatic Discharge (ESD) Immunity Test
IEC 61000-4-3	Radiated, radio-frequency, electromagnetic field immunity test
IEC 61000-4-4	Electrical Fast Transient / Burst immunity test
IEC 61000-4-5	Surge Immunity test
IEC 61000-4-6	Conducted Susceptibility (Immunity to conducted disturbances, induced by radio-frequency fields)
IEC 61000-4-8	Power frequency magnetic field immunity test
IEC 61000-4-29	Voltage dips & immunity tests for DC input ports
IEC 61010-1	Di-electric Strength (Safety requirements for electrical equipment for measurement, control, and Laboratory use)
CISPR-11/14-1	Conducted & Radiated Emissions

RoHS Directive 2011/65/EU of the European Parliament & of the council regarding the limitation of dangerous substances,

Year in which CE Marking was affixed: 2016

Name of Company: General Industrial Controls Pvt. Ltd.

Date: 22/06/2021

Name of Signatory: Rajan Rane Title / Designation: Manager (Product Engg)	Name of Signatory: Vijay Waykole Title / Designation: General Manager (Material Management)	Name of Signatory: Shrihari kshirsagar. Title / Designation: Manager (Quality)
<i>Rajan H. R.</i>		<i>SKshirsagar</i>

Document Ref. No: EC04321