

# General Industrial Controls Private Limited



## EU & RoHS Declaration of Conformity

We,

**General Industrial Controls Private Limited**, T-107 & T-114, MIDC, Bhosari, Pune 411 026 (Maharashtra State) India +91-20-46232323, [info@gicindia.com](mailto:info@gicindia.com), [www.gicindia.com](http://www.gicindia.com); declare under sole responsibility that the following described products in our delivered version comply with the appropriate basic safety and health requirements of the:

1. Low Voltage Directive – 2014/35/EU	2. EMC Directive – 2014/30/EU	3. RoHS Directive 2011/65/EU
---------------------------------------	-------------------------------	------------------------------

based on its design and type, as brought into circulation by us.

**(In case of alteration of the product by the user, not agreed upon by us, this declaration will lose its validity.)**

### Description of the Product:

**Series : Supply Monitoring Series (SM 175)**

Sr. No.	Catalog Numbers
1	MG21D2,MK21D5, MC21D5, MN21D5, MA21DN, MD21DF,MG21DH,MG21DF,MGD1DR,MG21D2,MOG1D51, MG21D2RI,MG21D2RH,MG21D2RG & MG21DFSK

### Generally meets Product Standard : IEC 60255-1

### Applicable Harmonized Standards: Under EMC & LVD Directives:




Ref. No.	Title
IEC 61000-4-2	Electrostatic Discharge (ESD) Immunity Test
IEC 61000-4-3	Radiated, radio-frequency, electromagnetic field immunity test
IEC 61000-4-4	Electrical Fast Transient / Burst immunity test
IEC 61000-4-5	Surge Immunity test
IEC 61000-4-6	Conducted Susceptibility (Immunity to conducted disturbances, induced by radio-frequency fields)
IEC 61000-4-8	Power frequency magnetic field immunity test
IEC 61000-4-11	Voltage dips & immunity tests for AC input ports
IEC 61010-1	Di-electric Strength (Safety requirements for electrical equipment for measurement, control, and Laboratory use)
CISPR-11	Conducted & Radiated Emissions

**RoHS Directive 2011/65/EU** of the European Parliament & of the council regarding the limitation of dangerous substances,

Year in which CE Marking was affixed: 2016

Name of Company: General Industrial Controls Pvt. Ltd.

Date: 30/03/2021

Name of Signatory: Rajan Rane Title / Designation: Manager (Product Engg)	Name of Signatory: Vijay Waykole Title / Designation: General Manager (Material Management)	Name of Signatory: Shrihari kshirsagar. Title / Designation: Manager (Quality)
Rajan H. R.		S. Kshirsagar
		

**Document Ref. No: EC0921**

T-107, M.I.D.C., Bhosari, Pune, 411 026, INDIA. Tel: +91 (0) 20 46232323

# General Industrial Controls Private Limited



## EU & RoHS Declaration of Conformity

We,

**General Industrial Controls Private Limited**, T-107 & T-114, MIDC, Bhosari, Pune 411 026 (Maharashtra State) India +91-20-46232323, [info@gicindia.com](mailto:info@gicindia.com), [www.gicindia.com](http://www.gicindia.com); declare under sole responsibility that the following described products in our delivered version comply with the appropriate basic safety and health requirements of the:

1. Low Voltage Directive – 2014/35/EU	2. EMC Directive – 2014/30/EU	3. RoHS Directive 2011/65/EU
---------------------------------------	-------------------------------	------------------------------

based on its design and type, as brought into circulation by us.

*(In case of alteration of the product by the user, not agreed upon by us, this declaration will lose its validity.)*

### Description of the Product:

**Series: Supply Monitoring Series (SM 175)**

Sr. No.	Catalog Numbers	Description
1	MAG03D0424	1M MSMR,3P-3W/3P-4W CONF.,208 to 480VAC +/-23%, SETTABLE REF. VTG & 10% FIXED ASY.
2	MAG03D0425	1M MSMR,3P-3W/3P-4W CONF.,415VAC +/-35%, FIXED REF. VTG & 10% FIXED ASY.
3	MAG03D0426	1M MSMR,3P-3W/3P-4W CONF.,415VAC +/-35%, FIXED REF. VTG & SELECTABLE UV OR ASY.
4	MAG03D0427	1M MSMR, 3P-3W, 415VAC +/-35%, PHASE LOSS RELAY
5	MAG03D042409	1M MSMR,3P-3W/3P-4W CONF.,208 to 480VAC +/-23%, SETTABLE REF. VTG & 10% FIXED ASY.
6	MAG03D0428	1M MSMR,3P-3W,415VAC +/-45% ,PHASE SEQUENCE RELAY

### Generally meets Product Standard : IEC 60255-1

### Applicable Harmonized Standards: Under EMC & LVD Directives:

Ref. No.	Title
IEC 61000-4-2	Electrostatic Discharge (ESD) Immunity Test
IEC 61000-4-3	Radiated, radio-frequency, electromagnetic field immunity test
IEC 61000-4-4	Electrical Fast Transient / Burst immunity test
IEC 61000-4-5	Surge Immunity test
IEC 61000-4-6	Conducted Susceptibility (Immunity to conducted disturbances, induced by radio-frequency fields)
IEC 61000-4-8	Power frequency magnetic field immunity test
IEC 61000-4-11	Voltage dips & immunity tests for AC input ports
IEC 61010-1	Di-electric Strength (Safety requirements for electrical equipment for measurement, control, and Laboratory use)
CISPR-11	Conducted & Radiated Emissions

**RoHS Directive 2011/65/EU** of the European Parliament & of the council regarding the limitation of dangerous substances,  
Year in which CE Marking was affixed: 2018

Name of Company: General Industrial Controls Pvt. Ltd.

Date: 09/11/2021

Name of Signatory: Rajan Rane Title / Designation: Manager (Product Engg)	Name of Signatory: Vijay Waykole Title / Designation: General Manager (Material Management)	Name of Signatory: Shrihari kshirsagar. Title / Designation: Manager (Quality)
Rajan H. R.		skshirsagar

**Document Ref. No: EC0921**

T-107, M.I.D.C., Bhosari, Pune, 411 026, INDIA. Tel: +91 (0) 20 46232323

# General Industrial Controls Private Limited



## EU & RoHS Declaration of Conformity

We,

**General Industrial Controls Private Limited**, T-107 & T-114, MIDC, Bhosari, Pune 411 026 (Maharashtra State) India +91-20-46232323, [info@gicindia.com](mailto:info@gicindia.com), [www.gicindia.com](http://www.gicindia.com); declare under sole responsibility that the following described products in our delivered version comply with the appropriate basic safety and health requirements of the:

1. Low Voltage Directive – 2014/35/EU	2. EMC Directive – 2014/30/EU	3. RoHS Directive 2011/65/EU
---------------------------------------	-------------------------------	------------------------------

based on its design and type, as brought into circulation by us.

**(In case of alteration of the product by the user, not agreed upon by us, this declaration will lose its validity.)**

### Description of the Product:

**Series** : SM Series  
**Nomenclature** : 1M UV OV  
**Cat ID** : MAE03D0200, MAE03D0201, MAE03D0202 & MAE03D0203.  
**Description** : Single phase under/over voltage relay

### Applicable Harmonized Standards: Under EMC & LVD Directives:

Ref. No.	Title
IEC 61000-4-2	Electrostatic Discharge (ESD) Immunity Test
IEC 61000-4-3	Radiated, radio-frequency, electromagnetic field immunity test
IEC 61000-4-4	Electrical Fast Transient / Burst immunity test
IEC 61000-4-5	Surge Immunity test
IEC 61000-4-6	Conducted Susceptibility (Immunity to conducted disturbances, induced by radio-frequency fields)
IEC 61000-4-8	Power frequency magnetic field immunity test
IEC 61000-4-11	Voltage dips & immunity tests for AC input ports
IEC 61000-4-29	Voltage dips & immunity tests for DC input ports
IEC 61010-1	Di-electric Strength (Safety requirements for electrical equipment for measurement, control, and Laboratory use)
CISPR-11/14-1	Conducted & Radiated Emissions

**RoHS Directive 2011/65/EU** of the European Parliament & of the council regarding the limitation of dangerous substances,

Year in which CE Marking was affixed: 2018

Name of Company: General Industrial Controls Pvt. Ltd.

Date: 03/08/2020

Name of Signatory: Rajan Rane Title / Designation: Manager (Product Engg)	Name of Signatory: Vijay Waykole Title / Designation: General Manager (Material Management)	Name of Signatory: Shrihari kshirsagar. Title / Designation: Manager (Quality)
Rajan H. R.		S.Kshirsagar
CE		RoHS

**Document Ref. No: EC0920**